



- COOLER SPECIFICATIONS**
- CHECKED:
- ___ SIZE: 32'-0" x 8'-0" x 7'-6"
 - ___ PANEL THICKNESS: 3 1/2" WALLS, & 3 1/2" CEILING
 - ___ EXTERIOR FINISH: (01) 26 GA. STUCCO GALVANIZED
 - ___ INTERIOR FINISH: (01) 26 GA. STUCCO GALVANIZED
 - ___ CEILING TYPE: LAG DOWN
 - ___ SCREED TYPE: WOOD SCREED
 - ___ ROUGH OPENING: 75 1/4"
 - ___ 1/4" WAS ADDED TO MANUFACTURE'S OPENING HEIGHT & WIDTH
 - ___ SILL HEIGHT: 5"
 - ___ HEADER HEIGHT: 9 3/4"
 - ___ DOOR DESCRIPTION: 1 QTY 34" x 78" OVERLAP SELF-CLOSING DOOR
3 SIDED GASKET W/ BOTTOM SWEEP
 - ___ ACCESSORIES:
 - ___ (1) VAPOR PROOF LIGHT 115V. (BULB NOT INCLUDED)
 - ___ (1) SWITCH WITH PILOT LIGHT 115V.
 - ___ (1) DIAL THERMOMETER
 - ___ (1) COVE MOLDING
 - ___ (1) FORM TO RAIL CEILING HANGERS

IMPORTANT NOTICE!
THIS COOLER/FREEZER IS DESIGNED TO ONLY SUPPORT ITS OWN WEIGHT. STORAGE ON TOP, MOUNTING TO OR ADJOINING THE COOLER/FREEZER FOR ALL MANUFACTURER'S WARRANTIES. OUTDOOR COOLER/FREEZER MUST BE DESIGNED TO MEET STATE AND LOCAL SNOW LOAD AND LIVE LOAD REQUIREMENTS.

NOTICE:
CONCRETE AND TILE WORKERS THE SHEET METAL FACING INSIDE THIS WALK-IN MAY BE SUSCEPTIBLE TO SPALLING OR OXIDATION DUE TO EXCESSIVE MOISTURE CREATED BY HYDRATION OF CONCRETE TYPE MATERIALS. ALSO NOTE THAT EXTRA CARE MUST BE TAKEN WHEN USING MURIATIC ACID OR OTHER HARSH CLEANING MATERIALS ON THE INSIDE OR OUTSIDE OF THIS WALK-IN. IT IS EXTREMELY IMPORTANT THAT THE WALK-IN IS PROPERLY VENTILATED WHILE THE CONCRETE IS CURING.

WARNING:
ENGINEERED FOR ON-GRADE INSTALLATION. IF ALL OR ANY PORTION OF THIS WALK-IN IS TO BE INSTALLED IN A DEPRESSION.

IMPORTANT!
CARROLL COOLERS MUST KNOW IF YOU ARE USING QUARRY TILE IN THE WALK-IN OR BUTTING UP TO THE WALK-IN, ANY ROUGH OPENINGS FOR PASS THRU DOORS OR ACCESS DOORS WILL NEED TO BE MODIFIED TO ALLOW THE DOORS TO OPEN AND CLOSE PROPERLY.

____ ("BUYER") APPROVES IN ALL RESPECTS THE DRAWINGS PROVIDED BY CARROLL COOLERS, INC. ("SELLER") IN CONNECTION WITH SELLER'S QUOTE _____ DATED _____ 200Z AND/OR BUYER'S PURCHASE ORDER _____ DATED _____ 200Z. BUYER ACKNOWLEDGES AND AGREES THAT THE AGREEMENT BETWEEN BUYER AND SELLER CONSISTS OF THE (I) DESCRIPTIONS AND QUANTITIES OF THE GOODS STATED ON SUCH PURCHASE ORDER, AND (II) THE PRICE, DELIVERY DATES AND TERMS AND CONDITIONS STATED ON SUCH QUOTE. BUYER FURTHER ACKNOWLEDGES THAT SUCH TERMS AND CONDITIONS SUPERSEDE AND REPLACE ANY AND ALL TERMS AND CONDITIONS APPEARING ON OR IN BUYER'S PURCHASE ORDER FORM.

*** ATTENTION ***
PLEASE SIGN & CHECK BOX

Fax to Barr, Inc
920-231-1701

APPROVED AS DRAWN
 APPROVED AS NOTED
 REVISE AND RESUBMIT

SIGNATURE _____
PRINTED NAME _____ DATE _____

PLEASE READ
VERIFICATION OF ALL ITEMS ON APPROVAL IS THE CUSTOMER'S RESPONSIBILITY. ANY REVISIONS NECESSARY MUST BE NOTED ON THIS DRAWING. FINAL DRAWING WILL BE PRODUCED USING SIGNED APPROVAL DWG.

- CHECK LIST**
- DOOR SWING
 - DOOR SIZE
 - INT. FINISH
 - EXT. FINISH
 - DIMENSIONS
 - DISPLAY DOOR LOC.
 - DISPLAY DOOR OPENING
 - SILL HEIGHT
 - HEADER HEIGHT

REFRIGERATION SUPERSTORE
www.barrinc.com

BARR

(920) 231-1711
FAX (920) 231-1701